


## Field validation of the $\Delta$ RIX performance indicator for flow in complex terrain

Niels G. Mortensen and Ole Rathmann, Risø DTU, Denmark  
Andrew Tindal and Lars Landberg, Garrad Hassan, UK



Risø DTU  
National Laboratory for Sustainable Energy


## Introduction

- Motivation
- The ruggedness index (RIX)
- The performance indicator ( $\Delta$ RIX)
- Previous work and results
- Methodology
- Verification at sample wind farm sites
- Conclusions
- Recommendations
  - for rugged terrain
  - and in general

## Motivation

- Wind farms are installed in complex and steep terrain
  - flow separation when slopes are steeper than 30-40%
- Common engineering flow models designed for attached flow
  - WAsP and WAsP Engineering (Risø DTU): BZ model & LINCOM
  - WindFarm (ReSoft): MS Micro
- Common wind farm design software may employ WAsP calculations
  - GH WindFarmer (Garrað Hassan)
  - WindPRO (EMD International)
  - WindFarm (ReSoft)
- For any flow model applied in complex terrain, one needs to know
  - is flow separation likely to occur?
  - is situation outside the operational envelope of the flow model?
  - what are the qualitative and quantitative effects on the predictions?
  - can the effects be mitigated or corrected for?
- Analyses and results reported here based on the WAsP flow model


## Ruggedness index and $\Delta RIX$



- Slopes steeper than  $\theta_c$  are indicated by the thick red (radial) lines.

- **Ruggedness index, RIX**
  - fraction of terrain surface which is steeper than a critical slope  $\theta_c$
  - slopes evaluated along 72 radii
  - calculation radius  $\sim 3-5$  km
  - critical slope  $\theta_c \sim 0.3-0.4$
  - marks onset of flow separation
  - Design operational envelope for WAsP is when  $RIX = 0$
- **Performance indicator,  $\Delta RIX$** 
  - two sites involved: MET and WTG
  - $\Delta RIX \equiv RIX_{WTG} - RIX_{MET}$
  - $\Delta RIX = 0 \Rightarrow$  reliable prediction
  - $\Delta RIX < 0 \Rightarrow$  under-prediction
  - $\Delta RIX > 0 \Rightarrow$  over-prediction

## Prediction error vs. $\Delta RIX$ (EWEC 2006)



5 Risø DTU, Technical University of Denmark  
Garraff Hassan and Partners Limited

Field validation of the RIX performance indicator for flow in complex terrain 01.04.2008


## Methodology

- Comparisons of measured and/or predicted wind speeds
  - plot prediction error versus  $\Delta RIX$  for met. masts
  - find site-specific fitting constant ( $\alpha$ )
  - calculate corrected predictions
  - plot original and  $\Delta RIX$ -corrected data
  - mean bias and mean absolute error (MAPE)
- Eight wind farm sites with 30 meteorological masts
  - Italy, Morocco, N Europe, Spain, Portugal
  - anemometer levels from 10 to 60 m a.g.l.
  - $|\Delta RIX| > 0$ ; varies from 0-23%
  - all sites more or less outside operational envelope of model
- Prerequisites
  - sites selected so other effects are of minor importance: meso-scale effects, complicated land-use, forest effects, thermal effects, etc.
  - high-quality wind and topographical inputs

6 Risø DTU, Technical University of Denmark  
Garraff Hassan and Partners Limited

Field validation of the RIX performance indicator for flow in complex terrain 01.04.2008

## Case 1: Predictions when $|\Delta RIX| = 0$



### Profile predictions only!

- Three wind farm sites
- Five different met. masts
- Levels 10/40, 30/60, 10/20/30/40


- Mast 1 (30/60), RIX = 6%
- Mast 2 (30/60), RIX = 9%
- Mast 3 (10/40), RIX = 15%
- Mast 4 (10/40), RIX = 26%
- Mast 5 (10-40), RIX = 16%

### • $\Delta RIX = 0\%$

- MAPE = 1.3%

- Difficult comparison!
  - roughness lengths
  - stability effects
  - flow distortion

## Case 2: Predictions when $|\Delta RIX|$ is small



- Wind farm site with 28 turbine sites
- Two 60-m met. masts, 2 km apart
- Predictions for 60 m a.g.l.
- Location: Iberian Peninsula

- Mast X RIX = 6%
- Mast Y RIX = 9%
- Turbine sites RIX = 4% to 13%


### • $\Delta RIX$ masts = $\pm 3\%$

- $\Delta RIX_X = -2\%$  to 7%
- $\Delta RIX_Y = -5\%$  to 4%

### • Standard WAsP calculation

- $Y = 1.00 \cdot X$
- MAPE = 0.3%

### Case 3: Predictions when $|\Delta RIX|$ is small




- Eight 30-50 m masts, up to 8 km apart
- Predictions for 30-50 m a.g.l.
- Location: Italy

- Mast 1, RIX = 2%
- Mast 2, RIX = 1%
- Mast 3, RIX = 1%
- Mast 4, RIX = 1%
- Mast 5, RIX = 1%
- Mast 6, RIX = 0%
- Mast 7, RIX = 1%
- Mast 8, RIX = 1%

- $\Delta RIX$  masts =  $\pm 2\%$

- Standard WAsP calculation
  - $Y = 1.00 \cdot X$
  - MAPE = 5.7%

### Case 3: Predictions when $|\Delta RIX|$ is small




- Eight 30-50 m masts, up to 8 km apart
- Predictions for 30-50 m a.g.l.
- Location: Italy

- Mast 1, RIX = 2%
- Mast 2, RIX = 1%
- Mast 3, RIX = 1%
- Mast 4, RIX = 1%
- Mast 5, RIX = 1%
- Mast 6, RIX = 0%
- Mast 7, RIX = 1%
- Mast 8, RIX = 1%

- $\Delta RIX$  masts =  $\pm 2\%$

- $\Delta RIX$ -corrections applied
  - $Y = 1.00 \cdot X$
  - MAPE = 5.7%

## Case 4: Predictions when $|\Delta RIX|$ is small




- Six 50-m met. masts, up to 5 km apart
- Predictions for 50 m a.g.l.
- Location: N Europe

- Mast 1, RIX = 11%
- Mast 2, RIX = 7%
- Mast 3, RIX = 8%
- Mast 4, RIX = 9%
- Mast 5, RIX = 5%
- Mast 6, RIX = 5%

- $\Delta RIX$  masts =  $\pm 6\%$

- Standard WAsP calculation
  - $Y = 1.00 \cdot X$
  - MAPE = 2.6% (SD = 2.1%)

## Case 4: Predictions when $|\Delta RIX|$ is small




- Six 50-m met. masts, up to 5 km apart
- Predictions for 50 m a.g.l.
- Location: N Europe

- Mast 1, RIX = 11%
- Mast 2, RIX = 7%
- Mast 3, RIX = 8%
- Mast 4, RIX = 9%
- Mast 5, RIX = 5%
- Mast 6, RIX = 5%

- $\Delta RIX$  masts =  $\pm 6\%$

- $\Delta RIX$ -corrections applied
  - $Y = 1.00 \cdot X$
  - MAPE = 2.5% (SD = 1.8%)

## Case 5: Predictions when $|\Delta RIX|$ is large



- Wind farm site with 25 turbine sites
- Two 40-m met. masts, 2.5 km apart
- Predictions for 40 m a.g.l.
- Location: Iberian Peninsula

- Mast X RIX = 15%
- Mast Y RIX = 26%
- Turbine sites RIX = 15% to 24%


### • $\Delta RIX$ masts = $\pm 11\%$

- $\Delta RIX_X$  = 0% to 9%
- $\Delta RIX_Y$  = -11% to -2%

### • Standard WAsP calculation

- $Y = 0.93 \cdot X$
- MAPE = 7.5%

## Case 5: Predictions when $|\Delta RIX|$ is large



- Wind farm site with 25 turbine sites
- Two 40-m met. masts, 2.5 km apart
- Predictions for 40 m a.g.l.
- Location: Iberian Peninsula

- Mast X RIX = 15%
- Mast Y RIX = 26%
- Turbine sites RIX = 15% to 24%


### • $\Delta RIX$ masts = $\pm 11\%$

- $\Delta RIX_X$  = 0% to 9%
- $\Delta RIX_Y$  = -11% to -2%

### • $\Delta RIX$ -corrections applied

- $Y = 1.00 \cdot X$
- MAPE = 1.3%

## Case 6: Predictions when $|\Delta RIX|$ is very large




- Five 10-m met. masts, 2-15 km apart
- Predictions for 10 m a.g.l.
- Location: Northern Portugal

- Mast 06, RIX = 28%
- Mast 07, RIX = 33%
- Mast 08, RIX = 18%
- Mast 09, RIX = 10%
- Mast 10, RIX = 11%

- $\Delta RIX$  masts =  $\pm 23\%$

- Standard WAsP calculation
  - $Y = 1.00 \cdot X$
  - MAPE = 14.9%

## Case 6: Predictions when $|\Delta RIX|$ is very large



- Five 10-m met. masts, 2-15 km apart
- Predictions for 10 m a.g.l.
- Location: Northern Portugal

- Mast 06, RIX = 28%
- Mast 07, RIX = 33%
- Mast 08, RIX = 18%
- Mast 09, RIX = 10%
- Mast 10, RIX = 11%

- $\Delta RIX$  masts =  $\pm 23\%$

- $\Delta RIX$ -corrections applied
  - $Y = 1.00 \cdot X$
  - MAPE = 1.7%



## Conclusions

- WAsP flow model generally works well for  $|\Delta\text{RIX}| < 5\%$ 
  - no improvement by applying  $\Delta\text{RIX}$ -procedure
  - large bias and scatter related to large distances and low wind speeds (mesoscale effects? thermal effects?)
- WAsP standard predictions significantly biased for  $|\Delta\text{RIX}| > 10\%$ 
  - magnitude and sign of bias explained by simple arguments
  - significant improvements by applying  $\Delta\text{RIX}$ -procedure
  - scatter increases only slightly with increasing  $\Delta\text{RIX}$
- $\Delta\text{RIX}$  correction procedure based on wind speed
  - works well for relatively 'uncomplicated' sites with steep slopes
  - $\ln(U_p/U_m)$  versus  $\Delta\text{RIX}$  fit is linear and goes through (0, 0)
  - fitting constant site-specific (0.7-1.5 for default parameters)
  - procedure easy to implement in WAsP
- Prediction of actual AEP for operating wind farm improved by 70%
  - from overestimation of 13% to 3% on AEP

## Best practices in rugged terrain

### Measurement programme [bankable]

- Two or more masts required
  - sited according to similarity principle (including forestry)
  - cover range of RIX over site
  - distances not greater than 1 km
  - supported by remote LT mast

### Topographical inputs

- Minimum size of map
  - Elevation: 10 km from any site
  - Land-use:  $\max(100 \times h, 10 \text{ km})$
- Detail and accuracy of map
  - wind farm site: 2-m contours
  - nearby terrain: 10-m contours
  - further away: 10-50 m contours
  - SRTM data may be used, but must be quality-controlled and detailed

### WAsP modelling

- RIX and  $\Delta\text{RIX}$  analyses required
- Use similarity principle if and when applying  $\Delta\text{RIX}$  correction procedure
- Standard heights in wind atlas
  - change one level to hub height
  - never change 10-m level!
- Standard roughnesses in wind atlas
  - other classes may be added or roughness lengths changed
  - never change  $z_0 = 0 \text{ m}$  class!
- Heat flux parameters
  - may be adapted to site

### Future

- Evidently, 'best practices' is not a long-term substitute for further research and improved models, such as CFD!